

<b>OMRON</b>
<b>形GX-JC03/JC06 EtherCAT 分岐 スレーブ</b>
<b>取扱説明書</b>
このたびは当社の形GX-JC03/JC06 EtherCAT分岐スレーブをお買い求めいただきまして誠にありがとうございました。安全にご使用いただくために、本紙を必ずお読みください。本説明書は、大切に保管していただくとともに、最終ユーザ様までお届けくださいますようお願いいたします。EtherCAT (R) はドイツのBeckhoff Automation GmbHの登録商標であり、特許で保護されている技術です。
©OMRON Corporation 2011 All Rights Reserved. <span style="float:right">2104229-8B</span>







## 安全上のご注意

- 警告／注意表示の意味**

<b>警告</b>	正しい取扱いをしなければ、この危険のために、軽症・中程度の傷害を負ったり、万一の場合には重症や死亡に至る恐れがあります。また、同様に重大な物的損害をもたらす恐れがあります。
-----------	--

<b>注意</b>	正しい取扱いをしなければ、この危険のために、時に軽症・中程度の傷害を負ったり、あるいは物的損害を受ける恐れがあります。
-----------	---

- 警告表示**

<b>警告</b>	
<p>通電中は、端子部に触れたり、本製品を分解して内部に触れたりしないでください。また、カバーを開けた状態で通電しないでください。感電の恐れがあります。</p>	
<p>本製品を分解して修理や改造はしないでください。感電の恐れがあります。</p>	
<p>信号線の断線、瞬時停電による異常信号などに備えて、ご使用者側でフェールセーフ対策を施してください。異常動作により重大な事故につながる恐れがあります。</p>	
<p>非常停止回路、インターロック回路、リミット回路など、安全保護に関する回路は必ず本製品の外部で制御回路を構成してください。</p>	
<p>本製品に入力する電圧／電流は、定められた範囲で入力してください。範囲外の電圧／電流を使用すると故障や火災の原因となります。</p>	
<b>注意</b>	
<p>直流電源を配線するときは、+/-極性に注意してください。接続を誤ると、システムが異常動作をする恐れがあります。</p>	


### 安全上の要点

- 製品を輸送するときは、専用の梱包箱を使用してください。また、輸送中に過度な振動や衝撃が加わらないように注意してください。
- DIN レール取付は、確実に行ってください。
- 複数のシステムにて使用する場合、干渉による動作の不安定を防ぐために、各ケーブル同士は、束ねずに必ず5mm 以上離してください
- 端子台、通信ケーブルなどロック機構のあるものは、必ずロックしていることを確認してからご使用ください。
- 通信距離および接続台数は仕様範囲内でご使用ください。
- 配線および施工の際は、製品内部に金属屑がはいらないように注意してください。
- 通信ケーブル、コネクタは必ず指定のものをご使用ください。
- 配線時は端子の極性に注意してください。
- 本説明書で指定した電源電圧で使用してください。
- ケーブルを無理に曲げたり、引張ったりしないでください。
- 通信ケーブルの配線時には、以下の注意を守ってください。
  - 通信ケーブルは、動力線、高圧線からは離してください。
  - 通信ケーブルを折曲げないでください。
  - 通信ケーブルを過度に引張らないでください。
  - 通信ケーブルにものを載せないでください。
  - 通信ケーブルは、必ずダクト内に配線してください。
- 接地された金属に触れるなどして、人体の静電気を放電させてからユニットに触れてください。
- PLC およびすべてのスレーブをOFFにして、通信ケーブルを配線してください。
- 電源事情が悪い場所では、定格の電圧や周波数の電源を供給できるようにしてご使用ください。

- 外部配線の短絡に備えて、ブレーカを設置するなど安全対策を施してください。
- 信号線の断線、瞬間停電による異常信号などに備えて、ご使用者側でフェールセーフ対策を施してください。
- 作成したユーザプログラムは、十分な動作確認を行った後、本運転に移行してください。
- 配線やスイッチの設定に間違いがないかを十分確認してから通電してください。

### 使用上の注意

- 本説明書に示すとおり、正しく設置してください。正しく設置しないと、故障するおそれがあります。
- 製品を落下させたり、異常な振動や衝撃を加えたりしないでください。故障や誤動作の原因になります。
- 次のような環境には設置しないでください。
  - 日光が直接当たる場所
  - 周囲温度や相対湿度が仕様値の範囲を超える場所
  - 温度の変化が急激で結露するような場所
  - 腐食性ガス、可燃性ガスのある場所
  - ちり、ほこり、塩分、鉄粉が多い場所
  - 水、油、酸、薬品などの飛沫がかかる場所
  - 本体に直接振動や衝撃が伝わる場所
- 次のような場所で使用する際は、遮蔽対策を十分に行ってください。
  - 静電気などによるノイズが発生する場所
  - 強い電界や磁界が生じる場所
  - 放射能を被曝する恐れのある場所
  - 電源線が近くを通る場所
- 本説明書に示すとおり、正しく配線してください。
- 配線をする際は、正しい配線部品をご使用ください。
- 通信路と電源の配線時には、電圧仕様に注意してください。間違った場合、故障の原因となります。
- GX-JC06は全ポートにLANケーブルが接続されている時、先にポート4、 5、 6を外してから、ポート1、 2、 3を外してください。
- ノードの初期設定は「0」になっています。使用時にツールで設定してください。
- 本スレーブは、弊社製品のEtherCAT対応位置制御ユニット形CJ1W-NC□81/□82とは接続できません。

<b>各部の名称</b>
 <p>表示 LED PWR: 電源</p> <p>LAN ポート 3ポート: GX-JC03 6ポート: GX-JC06 L/A LED: Link, ACT</p> <p>電源コネクタ</p> <ul style="list-style-type: none"><li>● +24V</li> <li>● GND</li> <li>● FG (接地端子)</li></ul> <p>FK-MCP1.5/3-ST-3.81</p>

- 表示 LED**

PWR	緑	消灯: 電源OFF 点灯: 電源ON
L/A	緑	消灯: 接続なし、又は接続時リンク確立せず 点灯: リンク確立, データ通信なし 点滅: リンク確立, データ通信中

- LAN ポート**

ユニット表示	ツール表示	説明
1/IN	IN	Port1 (IN port)
2	X2	Port2 (OUT port)
3	X3	Port3 (OUT port)
4	X4	Port4 (OUT port)
5	X5	Port5 (OUT port)
6	X6	Port6 (OUT port)


## UL規格/CSA規格適合のための注意事項

米国またはカナダで本製品をご使用になるお客様へ

本製品は UL規格 (UL1604)/CSA 規格No.22. 2 に対応しておりますが、UL 規格/CSA 規格の適合条件を満足するためには、お客様に以下の内容にご注意していただく必要があります。なおこの内容は米国およびカナダの電気工事配線規定に従った配線条件となっており、製品のマニュアルや安全上のご注意に記載している内容と異なる場合があります。

- ユニット電源コネクタへの配線**

ユニット電源には絶縁電源を使用し、制限電流4A の過電流保護を入れてください。



電線サイズ	制限電流
24 AWG	2A
22 AWG	3A
20 AWG	4A

- 通信電源の適用電線**

線種	適用電線サイズ	むき線長さ
単線／撚線	AWG16-24	9mm


棒端子での配線は使用せず、直接単線または撚線を端子台の穴に挿入してください。

- LAN ケーブル**

仕様	説明
ツイストペアケーブル (下記コネクタ付き可)	100BASE-TX 対応(カテゴリ5以上) <p>二重シールド (アルミテープ＋編組)</p>
RJ45コネクタ	カテゴリ5以上シールド対応

- 取り付け方向**

垂直方向に取り付けてください。



- Class I、Div. 2 への適合について**

入出力配線はClass I、Div. 2 の配線方法に従って配線してください。

- この機器はClass I、Div. 2、グループA、B、C、D または危険場所以外のみ適合しています。
- 警告：爆発の危険

部品の交換はClass I、Div. 2 の適合性を損なう可能性があります。
- 警告：爆発の危険

機器の電源状態や周囲の安全性が不明な場合は機器を外さないでください。

## トラブルシューティング

PWR	L/A	内容	原因	対策
消灯	消灯	電源供給異常	①電源未供給、電源未接続 ②内部回路故障	①電源供給と電源ケーブルの配線を確認 ②本体の交換
点灯	消灯	リンク未確立	①LANケーブルの抜け、未接続、短路 ②スレーブのハードウェア故障 ③マスターの未起動	①LANケーブルの接続確認。断線、短路の場合は、LANケーブルの交換 ②本体の交換 ③マスターのステータス確認

## 一般仕様

電源電圧	DC 20.4V~28.8V
消費電流	GX-JC03: 80mA; GX-JC06: 170mA
使用周囲温度	-10 ～ 55 <span> </span> °C
使用周囲湿度	25% ～ 85%（結露のないこと）
保存周囲温度	-25 ～ 65 <span> </span> °C
保存周囲湿度	25% ～ 85%（結露のないこと）
外形寸法	GX-JC03: 25mm×78mm×90mm; GX-JC06: 48mm×78mm×90mm

## EC指令の適合について

- この商品はシステムに組み込まれた状態で、EMC 指令に適合しています。お客様の機械・装置をEC 指令に適合させるにあたり、以下の注意が必要です。
  - 本製品は、必ず制御盤内に設置してください。
  - DC 電源ユニットおよび I/O ユニットに接続する DC電源は、強化絶縁、または二重絶縁されたものを使用してください。
  - (EN61131-2, EN61000-6-4) に適合していますが、特に Radiated emission (10m 法)に関しては、ご使用になる制御盤の構成、接続される他の機器との関係、配線等により変化することがあります。したがって、EC 指令適合品である本製品をご使用の場合でも、お客様にて機械・装置全体でEC 指令適合性を確認・対応していただく必要があります。
- この商品は「class A」（工業環境商品）です。住宅環境でご利用されると、電波妨害の原因となる可能性があります。その場合には電場妨害に対する適切な対策が必要となります。
- 推奨電源（形S8V）にて、EMC規格の適合性を確認しています。

<b>ご使用に際してのご承諾事項</b>
<p>下記用途に使用される場合、当社営業担当者までご相談のうえ仕様書などによりご確認いただくとともに、定格・性能に対し余裕を持った使い方や、万一故障があっても危険を最小にする安全回路などの安全対策を講じてください。</p> <p>a) 屋外の用途、潜在的な化学的汚染あるいは電氣的妨害を被る用途またはカタログ・取扱説明書などに記載のない条件や環境での使用</p> <p>b) 原子力制御設備、焼却設備、鉄道・航空・車両設備、医用機械、娯楽機械、安全装置、および行政機関や個別業界の規制に従う設備</p> <p>c) 人命や財産に危険が及ぶうるシステム・機械・装置</p> <p>d) ガス、水道、電気の供給システムや24時間連続運転システムなど高い信頼性が必要な設備</p> <p>e) その他、上記a)～d) に準ずる、高度な安全性が必要とされる用途</p> <p>*上記は適用用途の条件の一部です。当社のベスト、総合カタログ、データシート等最新版のカタログをよく読んでご使用ください。</p>

### オムロン株式会社

<p><b>●お問い合わせ先</b> カスタマサポートセンタ</p> <p> <b>0120-919-066</b> </p> <p><small>携帯電話・PHSなどではご利用いただけませんので、その場合は下記電話番号へおかけください。</small> 電話 <b>055-982-5015</b> (通話料がかかります)</p> <p><b>【技術のお問い合わせ時間】</b>  ■営業時間：8:00～21:00 <span style="float:right">■営業 日：365日</span>  ■上記フリーコール以外のFAシステム機器の技術窓口：  電話 <b>055-977-6389</b> (通話料がかかります)</p> <p><b>【営業のお問い合わせ時間】</b>  ■営業時間：9:00～12:00/13:00～17:30 (土・日・祝祭日は休業)  ■営業 日：土・日・祝祭日/春期・夏期・年末年始休暇を除く</p> <p><b>●FAXによるお問い合わせは下記をご利用ください。</b>  カスタマサポートセンタ お客様相談室 FAX 055-982-5051</p> <p><b>●その他のお問い合わせ先</b>  納期・価格・修理・サンプル・仕様書は貴社のお取引先、または貴社担当オムロン営業員にご相談ください。</p>
---

お断りなく仕様などを変更することがありますのでご了承ください。



# Model GX-JC03/JC06 EtherCAT Junction Slave

## Instruction Manual

Thank you for purchasing an OMRON EtherCAT Junction slave, Model GX-JC03/JC06. To secure safe operation, please be sure to read this manual. Keep this instruction manual in a safe location and be sure that it is readily available to your final users of the product. EtherCAT<sup>(R)</sup> is registered trademark and patented technology, licensed by Beckhoff Automation GmbH, Germany.

©OMRON Corporation 2011 All Rights Reserved. 2104229-8B

## Safety Precautions

- Meanings of Signal Words

**Warning** Indicates a potentially hazardous situation which, if not avoided, could result in death or serious injury. Additionally, there may be severe property damage.

**Caution** Indicates a potentially hazardous situation which, if not avoided, may result in minor or moderate injury, or property damage.

- Warning Symbols

### Warning

Do not attempt to disassemble this unit and do not touch the interior of any Unit while the power is being supplied. In addition, do not turn on electricity in the state that founded a cover. Doing so may result in electric shock.

Do not attempt to disassemble, repair, or modify this unit. Any attempt to do so may result in malfunction, fire, or electric shock.

Take a fail-safe countermeasures by the customer to secure safety in case of an abnormal signal caused by broken signal line and momentary power interruption. Not doing so may result in serious accidents.

Emergency stop circuits, interlock circuits, limit circuits, and similar safe measures must be externally provided to Slave Unit.

Do not apply the voltage/current outside the specified range to this product. It may cause a malfunction or fire.

### Caution

Pay careful attention to the polarities(+/-) when the DC power supply. A wrong connection may cause malfunction of the system.

## Precautions for Safe Use


- When transporting this product, use special packing boxes and protect it from being to excessive vibration or impact during transportation.
- Mount the Units securely using DIN track.
- Always separate cables by at least 5 mm to prevent unstable operation due to interference. Do not bundle cables.
- Make sure that the terminal blocks, communications cables, and other items with locking devices are properly locked into place. Improper locking may result in malfunction.
- Do not extend connection distances or the number of connected nodes beyond the ranges given in the EtherCAT specifications.
- Do not allow foreign matter to enter this product.
- Always use the specified communications cables and connectors.
- Confirm the polarity of all terminals before wiring them.
- Always use the power supply voltage specified in the instruction manual. An incorrect voltage may result in malfunction or burning.
- Do not bend cables past their natural bending radius or pull on cables.
- Observe the following precautions when wiring the communications cable.
  - Separate the communications cables from the power lines or high-tension
  - Do not bend the communications cables past their natural bending radius.
  - Do not pull on the communications cables.
  - Do not place heavy objects on top of the communications cables.
  - Always lay communications cable inside ducts.
- Be sure to ground when installing the unit.
- Turn off the power of Controller and all slaves before wiring the communication
- Take appropriate measures to ensure that the specified power with the rated voltage and frequency is supplied. Be particularly careful in places where the power supply is unstable. An incorrect power supply may result in malfunction.
- Install external breakers and take other safety measures against short-circuiting in external wiring. Insufficient safety measures against short-circuiting may result in burning.

- Fail-safe measures must be taken by the customer to ensure safety in the event of incorrect, missing, or abnormal signals caused by broken signal lines, momentary power interruptions, or other causes.
- Check the user program for proper execution before actually running it on the Unit. Not checking the program may result in unexpected operation.
- Check all wiring and switch settings to be sure they are correct.

## Precautions for Correct Use

- Install correctly according to instructions in the instruction manual. Improper installation of the Unit may result in malfunction.
- Do not drop any Unit or subject any Unit to excessive shock or vibration. Otherwise, Unit failure or malfunction may occur.
- Do not operate the control system in the following locations:
  - Locations subject to direct sunlight.
  - Locations subject to temperatures or humidity outside the range specified in the specifications.
  - Locations subject to condensation as the result of severe changes in temperature.
  - Locations subject to corrosive or flammable gases.
  - Locations subject to dust (especially iron dust) or salts.
  - Locations subject to exposure to water, oil, acid, or chemicals.
  - Locations subject to shock or vibration.
- Take appropriate and sufficient countermeasures when installing systems in the following locations:
  - Locations subject to static electricity or other forms of noise.
  - Locations subject to possible exposure to radioactivity.
  - Locations close to power lines.
  - Locations subject to strong electromagnetic fields.
- Wire all connections correctly according to instructions in the instruction manual.
- Use the correct wiring materials to wire the Units.
- Confirm voltage specifications when wiring communications, the power supply. Incorrect wiring may result in malfunction.
- Please pull out the connector inserted in Port 4,5,6 at first when all the ports of GX-JC06 is used.
- Default node setting is 0, please set the node by tool.
- Please do not connect EtherCAT Junction unit with OMRON position control unit, Model CJ1W-NC□81/ □82.

## Each Part Name



■ LED		
PWR	Green	Extinction: Power OFF Lit: Power ON
L/A	Green	Extinction: No connect or No link when connection Lit: Link, No data communication Blinking: Link, Data communication


■ LAN PORT			
Name on Unit	Name on Tool	Detail	
1/IN	IN	Port1 (IN port)	
2	X2	Port2 (OUT port)	
3	X3	Port3 (OUT port)	
4	X4	Port4 (OUT port)	
5	X5	Port5 (OUT port)	
6	X6	Port6 (OUT port)	

## Precautions for Compliance with UL Standatds and CSA Standards

**Notice to Users of EtherCAT Junction Slave in the USA and**  
Please use the following installation information instead of the general information in the instruction manuals in order to use the product under certified conditions of UL and CSA when the product is installed in the USA or Canada. These conditions are required by NFPA 70, National Electrical Code in the USA and the Canadian Electrical Code, Part in Canada and may vary from information given in the product manuals or safety precautions.

## ■ Wiring for Unit power connector

The external power supply must be an isolated DC source. It must be equipped with an over-current protection with current limitation in 4A.



Minimum Wire size	Ampere rating of protection
24 AWG	2A
22 AWG	3A
20 AWG	4A

## ■ Applicable wire size for Unit power source terminal block.


Type	Wire size	Strip length
Solid/Strand	AWG16-24	9mm

Do not use ferrule terminals. Insert the strand or solid wire directly into the holes on the terminal block.

## ■ LAN Cable

Product name	Comment
Twist-pair cable (Cable with connectors below are also allowed)	100BASE-TX (Category 5 or higher) Double-shield (aluminum tape + braided shielding)
RJ45 connector	Category 5 or higher Shielded

## ■ Direction for installation



## ■ Compliance with Class I Division 2 Hazardous Location:

Input and output wiring must be in accordance with Class I Div.2 wiring methods and in accordance with the authority having jurisdiction.

- This equipment is suitable for use in Class I, Div.2, Group A, B, C, D or Non-Hazardous Locations Only.
  - WARNING : Explosion Hazard - Substitution of Components may Impair Suitability for Class I, Div.2.
  - WARNING : Explosion Hazard - Do not Disconnect Equipment Unless Power Has Been Switched off or the Area Is Known to Be Non-Hazardous.
  - This device is open-type and is required to be installed in an enclosure suitable for the environment and can only be accessed with the use of a tool or key.
- Cet equipement convient a l'utilisation dans des emplacements de Classe I, Division 2, Groupes A, B, C, D, ou ne convient qu'a l'utilisation dans des endroits non dangereux.
  - AVERTISSEMENT : Risque d'explosion - La substitution de composants peut rendre ce materiel inacceptable pour les emplacements de Classe I, Division 2.
  - AVERTISSEMENT : Risque d'explosion - Avant de debrancher l'equipement, couper le courant ou s'assurer que l'emplacement est designe non dangereux.
  - Ce dispositif est de type ouvert et doit etre installe dans un coffret adapte a l'environnement et auquel on ne pourra acceder uniquement au moyen d'un outil ou d'une cle.

## Troubleshooting

[PWR] indicator	[L/A] LED	Contents	Cause	Measures
OFF	OFF	Power supply error	①Without power supply, power supply disconnection ②Internal power supply is broken.	①Check the power supply unitand cables. ②Replace the slave.
ON	OFF	Without establishing Link	①Communication cable comes off, disconnection and short. ②Slave's hardware is broken. ③Host master hasn't been started	①Check the connection of communication cable, Change the communication cable ② Replace the slave ③ Check status of the host master.

## Specification

Power supply Voltage	DC 20.4V~28.8V
Consumption Electric Power	GX-JC03: 80mA; GX-JC06: 170mA
Ambient operating temperature	-10 to 55 °C
Ambient operating humidity	25% to 85% (with no condensation)
Storage temperature	-25 to 65 °C
Storage humidity	25% to 85% (with no condensation)
Dimension	GX-JC03: 25mm×78mm×90mm; GX-JC06: 48mm×78mm×90mm

## Conformance to EC Directives

- This product is EMC-compliant when assembled in PLC system . To ensure the EC Directive conformance of customer's machinery or equipment in which the product is incorporated, be sure to observe the following precautions.
  - This product is defined as an in-panel device and must be installed within a control panel.
  - Reinforced insulation or double insulation must be used for the DC power supply connected to the DC power supply unit, communication unit, and I/O unit.
  - This product complies with the common emission standard (EN61131-2, EN61000-6-4) with regard to EMI. For the radiated emission requirement (10-m regulations), in particular, please note that the actual emission varies depending on the configuration of the control panel to be used, the connected devices, and wiring methods. Therefore, the customer must confirm the EC Directive conformance of the overall machinery or equipment by themselves, even if this EC conforming product is used.
- This is a class A product. In residential areas it may cause radio interference, in which case the user maybe required to take adequate measures to reduce interference.
- This product is EMC-compliant when the recommend power supply(S8\*\*) is used

## SUITABILITY FOR USE

OMRON shall not be responsible for conformity with any standards, codes, or regulations that apply to the combination of products in the customer's application or use of the products. Take all necessary steps to determine the suitability of the product for the systems, machines, and equipment with which it will be used. Please know and observe all prohibitions of use applicable to the products.

NEVER USE THE PRODUCTS FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCTS ARE PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

See also product catalogs for Warranty and Limitations of Liability.



OMRON Corporation  
Industrial Automation Company  
Tokyo, JAPAN

Contact: [www.ia.omron.com](http://www.ia.omron.com)

Regional Headquarter  
OMRON EUROPE B.V.  
Wegalaan 67-69-2132 JD Hoofddorp  
The Netherlands  
Tel: (31)2356-81-300  
Fax: (31) 2356-81-388.

OMRON ASIA PACIFIC PTE.LTD  
No.438A Alexandra Road # 05-05/08  
(Lobby 2), Alexandra Technopark,  
Singapore 119967  
Tel: (65) 6835-3011  
Fax: (65) 6835-2711

OMRON ELECTRONICS LLC  
One Commerce Drive Schaumburg,  
IL 60173-5302 U.S.A  
Tel: (1) 847-843-7900  
Fax: (1) 847-843-7787

OMRON (CHINA) CO., LTD.  
Room 2211, Bank of China Tower,  
200 Yin Cheng Zhong Road,  
Pu Dong New Area, Shanghai,  
200120, China  
Tel: (86) 21-5037-2222  
Fax: (86) 21-5037-2200

Note: Specifications subject to change without notice.